



Certificate of Compliance

Certificate: 2472857

Master Contract: 231723

Project: 2472857

Date Issued: January 11, 2012

Issued to: Limatherm SA

ul. Tarnowska 1
Limanowa, 34-600
Poland
Attention: Janik Honorata

The products listed below are eligible to bear the CSA Mark shown



Jelena Dzeletovic

Issued by: Jelena Dzeletovic

PRODUCTS

CLASS 2258 02 - PROCESS CONTROL EQUIPMENT - For Hazardous Locations

Class I, Div. 1, Groups A, B, C and D; Class II, Div. 1, Groups E, F and G, Class III, Div. 1; Type 4X:

XD-JB85 Series – Universal Box – with window or blind cover; -40 Deg. C < Ambient < + 85 Deg. C (models with “win” in model code); -40 Deg. C < Ambient < + 200 Deg. C (models without “win” in model code).

XD-JB85a-b-c/d-c/d-c/d-ef+g. Universal Box.

a = Version BLANK, win, l or lwin.

b = Seal material 0, 3, 4 or 5.

c = Entry thread N2, N3 or CD.

d = Entry plug BLANK or PD.

e = Coating C, SE, SPU, P or E.

f = Color sh, yc, ys, bs, sb, sg, gr, ag, gs, cw or al.

g = Mounting plate BLANK or MP.

Note: The above housings are Certified for use only with other equipment where the suitability of the combination is to be determined by the CSA International.



Certificate: 2472857

Master Contract: 231723

Project: 2472857

Date Issued: January 11, 2012

APPLICABLE REQUIREMENTS

- CAN/CSA-C22.2 No. 0-M91 - General Requirements – Canadian Electrical Code, Part II
- C22.2 No. 25-1966 - Enclosures for Use in Class II, Groups E, F and G Hazardous Locations
- C22.2 No. 30-M1986 - Explosion-Proof Enclosures for Use in Class I Hazardous Locations
- CAN/CSA-C22.2 No. 94-M91 - Special Purpose Enclosures