



Member of the FM Global Group

FM Approvals
1151 Boston Providence Turnpike
P.O. Box 9102 Norwood, MA 02062 USA
T: 781 762 4300 F: 781-762-9375 www.fmapprovals.com

CERTIFICATE OF COMPLIANCE

HAZARDOUS (CLASSIFIED) LOCATION ELECTRICAL EQUIPMENT

This certificate is issued for the following equipment:

XD-JB85a-b-c/d-c/d-c/d-ef+g. Universal Box.

XP/I/1/ABCD; DIP/II,III/1/EFG; Type 4X

a = Version BLANK, win, I or Iwin.

b = Seal material 0, 3, 4 or 5.

c = Entry thread M2, M24, M25, M27, N2, N3 or CD.

d = Entry plug BLANK or PD.

e = Coating C, SE, SPU, P or E.

f = Color sh, yc, ys, bs, sb, sg, gr, ag, gs, cw or al.

g = Mounting plate BLANK or MP.

Equipment Ratings:

Explosionproof for Class I, Division 1, Groups A, B, C and D; Dust-ignitionproof for Class II, Division 1, Groups E, F and G, Class III hazardous (classified) locations, indoors and outdoors (Type 4X).

FM Approved for:

Limatherm SA
Limanowa, Poland

This certifies that the equipment described has been found to comply with the following Approval Standards and other documents:

| | |
|---------------|------|
| Class 3600 | 1998 |
| Class 3615 | 2006 |
| Class 3810 | 2005 |
| ANSI/NEMA 250 | 1991 |

Original Project ID: 3042541

Approval Granted: September 27, 2011

Subsequent Revision Reports / Date Approval Amended

| Report Number | Date | Report Number | Date |
|---------------|------|---------------|------|
|---------------|------|---------------|------|

FM Approvals LLC



J. E. Marquedant
Group Manager, Electrical

27 September 2011
Date